

Addendum Number Three

To the Drawings and Specifications for:
24/7 Travel Store, Goodland, Kansas

Issued: Wednesday, September 23, 2020

HANNEY & ASSOCIATES ARCHITECTS

1726 South Hillside, Wichita, Kansas

NOTICE TO BIDDERS:

You are hereby instructed to include in your bids the following changes, clarification and/or corrections to the Drawings and Specifications for **24/7 Travel Store, Goodland, Kansas**.

The additions and/or corrections shall be considered as a part of the Contract Documents as if incorporated therein. Where the following corrections and/or additions vary from the conditions of the Drawings and Specifications, such following changes or additions shall govern.

I. GENERAL CLARIFICATIONS:

- 1.1 Bid Date
The Bid Date is unchanged and remains Thursday, September 24, 2020.
The time and location to receive the bids remains unchanged.
- 1.2 Bid Procedure
Email bids will be accepted. Please email bids to:
marka@triplettinc.com and martin@haarchitects.com.
- 1.3 Construction Testing and General Contractor's Base Bid
Testing will be required for soil compaction, concrete, masonry, and steel.
The fees for testing shall be included in the General Contractor's Base Bid.
- 1.4 Special Equipment
For the coffee kiosk and Storage Room 209, the Caribou Coffee furnishings and equipment shall be provided by Tenant, and installed by General Contractor.
All finishes shown on drawings shall be provided and installed by General Contractor.

II. CHANGES TO SPECIFICATIONS:

- 2.1 Section 07510 – TPO Roofing
Johns-Manville is an Acceptable Roofing System manufacturer.

III. CHANGES TO DRAWINGS:

- 3.1 Sheet A7.5
The reference to FSC Certification is removed. FSC Certification is not required for the cabinetry/millwork on this project.
- 3.2 Sheet AS.10
The existing external pylon sign shall be relocated by the Owner.
- 3.3 Sheet EQ-1
General Contractor shall provide power for refrigeration equipment, but shall not install refrigeration equipment. Please refer to Sheet EQ-2.

END OF ADDENDUM