



A STORM SHELTER - SPECIAL SYSTEMS
SCALE: 1/8" = 1'-0"
NORTH



B INDUSTRIAL ARTS PLAN - SPECIAL SYSTEMS
SCALE: 1/8" = 1'-0"
NORTH

GENERAL NOTES:

- ALL CIRCUITS INDICATED ON DRAWINGS SHALL BE 20A, 120V CIRCUITS WITH (2)-#12'S AND (1)-#12 G. IN 0.5" CONDUIT U.O.A.
- LABEL ALL SNAP SWITCH COVERPLATES WITH THE PANEL AND CIRCUIT NUMBER.
- REFER TO RELATED ARCHITECTURAL DRAWINGS FOR RELATED INFORMATION.
- REFER TO THE SPECIFICATIONS FOR DATA NOT ON THE DRAWINGS.
- WALL MOUNTING HEIGHTS TO CENTERLINE OF DEVICE UNLESS OTHERWISE NOTED.
- A GROUND CONDUCTOR SIZED PER N.E.C. ARTICLE 250 IS REQUIRED IN ALL POWER, RECEPTACLE, AND LIGHTING CIRCUITS. GROUND CONDUCTORS ARE NOT SHOWN ON DRAWINGS.

PLAN NOTES:

- XXXXXXXXXXXXXXXXXXXX

CONTRACTOR TO REFERENCE SHEET SPECIFICATIONS FOR MORE INFORMATION REGARDING FIRE ALARM SCOPE, INTERCOM SYSTEM INFORMATION, AND FIRE ALARM SERVICE AGREEMENT REQUIREMENTS.

ALL NEW ELECTRICAL DEVICES LOCATED WITHIN NEW WALLS SHALL BE RECESSED AND ALL NEW ELECTRICAL DEVICES LOCATED ON EXISTING WALLS (THAT ARE NOT BEING FURRED OUT) SHALL BE SURFACE MOUNTED. CONTRACTOR SHALL MAKE BEST EFFORT TO FEED ALL NEW SURFACE MOUNTED DEVICES FROM BEHIND TO MINIMIZE SURFACE MOUNTED RACEWAYS. CONTRACTOR SHALL COORDINATE WALL TYPES WITH ARCHITECTURAL DRAWINGS. CONTRACTOR TO VERIFY LOCATION OF ANY SURFACE MOUNTED RACEWAYS WITH ARCHITECT/ENGINEER PRIOR TO INSTALL. ANY SURFACE MOUNTED RACEWAYS SHALL BE PAINTED TO MATCH WALL COLOR. CONTRACTOR SHALL USE EMT CONDUIT FOR SURFACE MOUNT RACEWAYS IN METAL SHOPWOOD SHOP AND PLUGMOLD FOR SURFACE MOUNT RACEWAYS IN ALL OTHER LOCATIONS.

CONTRACTOR TO PROVIDE ALLOWANCE FOR (7) NEW DUCT MOUNTED SMOKE DETECTORS FOR EXISTING HVAC UNITS IN FINE ARTS, INDUSTRIAL ARTS, AND GYM AREA. CONTRACTOR SHALL COORDINATE EXACT INSTALLATION LOCATION WITH EACH UNIT.



HANNEY & ASSOCIATES, ARCHITECTS
1726 South Hillside, Wichita, Kansas, 67211
Phone (316) 683-8965
Fax (316) 684-1441
www.haarchitects.com

2019
OXFORD JUNIOR/SENIOR HIGH SCHOOL
UNIFIED SCHOOL DISTRICT #358
515 N Water St, Oxford, KS 67119

DRAWINGS ISSUED		
NO.	DATE	ITEM ISSUED
8	1/21/20	ADDENDUM #3
7	12/20/19	ISSUED FOR BIDS
6	12/16/19	99% BOARD REVIEW
5	12/13/19	99% SUBMITTAL
4	9/20/19	50% REVIEW
3	6/10/19	DESIGN DEVELOPMENT
2	5/13/19	SCHEMATIC DESIGN
1	4/8/19	SCHEMATIC DESIGN

COMPUTER DRAWING

DATE: AUGUST, 2019
DRAWN BY: CK CHECKED BY: DR

SHEET

E2.4

OF 1 SHEETS

