

**Addendum Number Two**

To the Drawings and Specifications for  
The North Re-Roofing Project  
For Oxford Jr/Sr High School  
Oxford, Kansas

Issued: August 5, 2019

**HANNEY & ASSOCIATES ARCHITECTS**

1726 South Hillside, Wichita, Kansas

**NOTICE TO BIDDERS**

You are hereby instructed to include in your bids the following changes and/or corrections to the Drawings and Specifications for the North Re-Roofing Project for USD #358, Oxford Jr/Sr High School, Oxford, Kansas.

The additions and/or corrections shall be considered as a part of the Contract Documents as if incorporated therein. Where the following corrections and/or additions vary from the conditions of the Drawings and Specifications, such following changes or additions shall govern.

**I. GENERAL CLARIFICATIONS:**

- 1.1 *The bid date shall remain Monday, August 12<sup>th</sup>, 2019 at 319 E. College, Oxford, Kansas 67219, up to and until 2 p.m.*
- 1.2 Carlisie Syntec, Sure-weld, TPO, roof system is an approved equal.
- 1.3 See attached detail:




EXISTING PARAPET WALL.

EXISTING THRU-WALL FLASHING IS TO REMAIN. CONTIN. RE-CAULK SEAM. TYP.

EXISTING REGLET IS TO BE REMOVED.

TURN NEW T.P.O. ROOFING UP PARAPET WALL AND TERMINATE UNDERNEATH EXISTING THRU-WALL FLASHING. USE TERMINATION BAR W/ CONTIN CAULKING SEAM AT TERMINATION POINT.




DETAIL - N.T.S.

EXISTING ROOF SYSTEM TO BE REMOVED. REFER TO DRAWINGS & SPECIFICATIONS.

AREA OF WORK. REFER TO A1.0

RED DASHED LINE INDICATES EXTENT OF FLASHING DETAIL.



**A ROOF PLAN**  
SCALE: 1" = 40'-0" NORTH



2019  
OXFORD JR/SR HIGH SCHOOL  
NORTH RE-ROOF

HANNEY & ASSOCIATES, ARCHITECTS

1726 South Hillside, Wichita, Kansas, 67211 Phone (316) 683-8965 Fax (316) 684-1441

DATE	ITEM
8/5/19	ADDENDUM #2